

PAT4 COMPACT APPLIANCE TESTING CERTIFICATE

Certificate No.: 6

This form allows data to be imported from: **Megger PAT4**



Serial No.: _____

CLIENT AND LOCATION DETAILS

Client Name and Address

BKE
TURNPIKE HSE
BRIDGE ST
ASHBOURNE

Location Name and Address

HEAD OFFICE
TURNPIKE HSE
ASHBOURNE

TEST RESULTS

Asset ID	Description	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
26003	GRILL	26/07/2006	Pass	0.007	0.007	-	2.64	1.465	0	Skip	-	P
26004	TOASTER	26/07/2006	Pass	0.022	>10	0.021	>50	0.902	0	Skip	-	P
26005	SANDWICH	26/07/2006	Pass	>10	>10	>10	>50	0.674	0	Skip	-	P
26006	KETTLE	26/07/2006	Pass	>10	>10	-	>50	1.905	0	Skip	-	P
26008	HEATER	26/07/2006	Pass	0.029	0.032	-	>50	1.563	0	Skip	-	P
26009	LEAD	26/07/2006	Pass	0.049	0.049	-	>50	-	-	Pass	-	P
26010	LEAD	26/07/2006	Pass	>10	-	-	-	0.011	0.38	Skip	-	P
26010	LEAD	26/07/2006	Pass	5.205	0.068	-	-	0.011	0.39	Skip	-	P
26011	LEAD	26/07/2006	Pass	0.055	-	-	>50	-	-	Pass	-	P
26013	LEAD	26/07/2006	Pass	0.06	-	-	>50	-	-	Pass	-	P
26014	PHOTOCOPIER	26/07/2006	Pass	>10	-	-	-	0.071	0.25	Skip	-	P
26015	LEAD	26/07/2006	Pass	0.059	-	-	>50	-	-	Pass	-	P
26016	PC	26/07/2006	Pass	1.634	0.034	-	-	0	0.27	Skip	-	P
26017	PLOTTER	26/07/2006	Pass	>10	-	-	-	0.073	0.37	Skip	-	P
26018	RADIO	26/07/2006	Pass	>10	-	-	-	0	0	Skip	-	P
26012	FAX	26/07/2006	Pass	2.121	-	-	-	0	0.15	Skip	-	P

CONTRACTOR DETAILS

Company Name and Address

Brian King Engineering
Turnpike House
Bridge St
Ashbourne
Co Meath

Tester Name Stephen Dolan

Qualifications Electrician

Position Test engineer

Signature _____